

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 269/2023-24.

Dated: 15/07/23

It is certified that an inspection team headed by Er. Kapil Joshi and R. Singh Ji

(Name of Officers with designation) from Sub Divisional Engineer, W/S Sanitation

(Name of Department/ Office) inspected the S.P. International School, Sarki - Zone Vng

(Name & Address of the school) on 15/07/23 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 03 years

Signature with Seal

Name

Designation :

Assistant Engineer of

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To Manager

S.P. Int School

Sarki Kesarakat

Jaunpur U.P.

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



**\* TEST REPORT \***

Name & Address of Customer: <b>S.P. INTERNATIONAL SCHOOL, SARKI KERAKAT - JAUNPUR U.P.</b>		Customer Reference No.	No: 1087/sk/23 Dated: 23/06/2023
		Sample Submitted by	AKASH SINGH
		Date of Sample Receipt	23/06/2023
		Analysis Starting Date	25/06/2023
		Analysis completion Date	03/07/2023
Discipline: Chemical Testing		Group: Water	
Test Report No.:	RWTL/SNG/2324/00078	Date of Issue:	03/07/2023
Registration no.:	RWTL/SNG/2324/REG2324/00267	Condition of Sample:	Unsealed
Source:	NA	Quantity/Type of Bottle:	1000 ml / Amber Colored Glass Bottle
Scheme:	NA	Location/Depth:	RO plant S.P. INTERNATIONAL SCHOOL, KERAKAT / NA
Village:	SARKI	Habitation:	NA
Block: -	KERAKAT	District:	JAUNPUR
Latitude:	NA	Longitude:	NA

Sample Type: Treated Water

Sr. No	Parameter	Result	As per 15-10500:2012 (2nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.75	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5-2018) (Second Revision)
4	TDS	280	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	IS 3025 (Part 21-2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	mS/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

*Ramesh Yadav*  
23/07/23  
Dr. Ramesh Yadav  
Quality Manager  
Authorized Signatory  
For, Regional Water Analysis,  
Laboratory Jan Nigam Varanasi – UP.

----- End of the Test Report -----